



THOMAS J. PASTUSZKA,
CMC, CCB
EXECUTIVE OFFICER/CLERK

County of San Diego
AIR POLLUTION CONTROL DISTRICT HEARING BOARD
1600 PACIFIC HIGHWAY, ROOM 402, SAN DIEGO, CALIFORNIA 92101-2471

TELEPHONE (619) 531-5777
FAX (619) 531-6098

STATEMENT OF PROCEEDINGS
SAN DIEGO COUNTY
AIR POLLUTION CONTROL DISTRICT HEARING BOARD
Regular Meeting, Thursday, April 26, 2012

ADMINISTRATIVE ITEM:

A. Approval of Minute Orders of April 12, 2012

ACTION: APPROVED

Petition No.

4363 ARE-10933 NORTH TORREY PINES, LLC/ADVANCED BIOHEALING INC:
Requests a Regular Variance (filed February 14, 2012) from District Rule 12 and 21, Condition No. 1 as applied to Permit Nos. APCD2006-PTO-961011, APCD2006-PTO-961012, APCD2006-PTO-950123, APCD2009-PTO-973610, APCD2005-PTO-979429 and 17 CCR 93115.6 involving a main service entrance breaker that is broken and needs a replacement, located at 10931 and 10933 North Torrey Pines Road, Ste. 200, San Diego, CA 92037. These diesel emergency engines, which range from 215 to 947 hp, are limited to either 20 or 30 hours testing and maintenance per year. The request is to run them for an additional 12 hours for calendar year 2012.

ACTION: ITEM WITHDRAWN BY PETITIONER: APRIL 25, 2012

LAST MATTER OF BUSINESS:

Opportunity for members of the Public to speak to the Board on any subject matter within the Board's jurisdiction but not on an item on today's Agenda. (Five minutes total will be allocated; each speaker's presentation may not exceed one minute and may not relate to pending litigation.)

ACTION: NO SPEAKERS

ASSISTANCE FOR THE DISABLED:

Agendas and records are available in alternative formats upon request. Contact the Clerk's office at **(619) 531-5777 (voice) or (619) 531-4803 (TTY)**. Assistive Listening Devices (ALDs) are available from the Clerk of the Board in Room 402 prior to the meeting, and are to be returned at the end of the meeting. Individuals requiring sign language interpreters should contact the Americans with Disabilities Coordinator at **(619) 531-5205**, in advance of the meeting so that arrangements may be made. An area in the front of the chamber is designated for individuals requiring the use of wheelchair or other accessible devices.